
B2 Garage Door + Buzzer



OakBridge Board

Tue 4/17/2018 3:37 PM

To: OakBridge Board (oakbridgenh@hotmail.com) ↗

↩ Reply | ▼

Good Afternoon,

4/17/2018

B2 garage door - The garage door in your building is in the open position as the garage door is stuck open. There has been no vandalism, and no one accidentally hit the garage door. The earliest the garage repair vendor can be here to fix the door is tomorrow 4/18. Please make sure you lock your car doors tonight as the garage is now open to the public.

B2 buzzer system – There is an issue with the power to B2 buzzer. Our wonderful cleaning guy trips the breakers on the first and third floors when he plugs in his vac-pack, which is a building issue, and has nothing to do with his vac-pack. One of these breakers also controls the building's buzzer unit. We have already scheduled our electric company to come trouble-shoot where the problem is and come up with a solution.

Is it spring yet?? BOD