


Visit by the Fire department on Saturday evening




Connie Garland 4:28 PM ▶



From: **cgarland@harvardmanagement.com** (cgarland@harvardmanagement.com) This sender is in your [contact list](#).

Sent: Mon 6/08/15 4:28 PM



Good afternoon everyone

The fire department and the gas company were called to building 3 this past Saturday because the CO2 detector in the garage sounded.

Luckily the fire department and the gas company found no issues with the gas lines. The CO2 device had a loose detector. The device was checked by Gagne Plumbing and they stated we should have no further issues with the device.